





谢拉林	SEES	谢拉林	SEES
Response Analysis!		We measured a lot of floor	vibrations and calculated
Ericsson gave us a number of critical		responses at critical modes.	
investigate, such as surface grinders.		We built a system around a	a single card computer and
Experimental Modal Analysis gave us	s the resonance	recorded raw and analyzed	data on digital magnetic
frequencies and mode shapes. Exam	iple:	tape. Reported frequently	to Vägverket and Ericsson.
First bending mode No relative motion beth First torsional mode No relative motion Second bending mode Relative motion	ween tool and work piece	The highway construction serious disturbances for Er	was finished in 1981 without icsson.
SEES November 2024	e	SEES Nover	nber 2024
































谢拉林	SEES	谢拉林	SEES
Svarthålsforsen was not allowed to chang water level.	ge upstream	Experimental Modal Analys	is of turbine blades in turbine.
Meant very different instant power prode water you have!	uction. Use the	PRESE &	RAEN, — STUDION AV INDYTUKSSKOVEL KVA NASTARA VISBERÄKNING
		Calculations and measurem	ents on model blade. Which
Maybe certain power levels dangerous fo turbine?	or the repaired	mode was to blame?	
		What to measure? Pressure	in turbine chamber!
We were contracted to find out and mon	itor!		
SEES November 2024	25	SEES Novemb	er 2024 26





谢拉林	SEES
We knew the critical vibration mode!	
Signal from pressure transducer in the turbine chamber was band pass filtered.	
Rms value of the filtered signal was shown in the control room.	
In that way they could avoid critical modes for the turbine.	
SEES November 2024	28














谢拉林	SEES	谢拉林	SEE
Wikipedia:		Vattenfall built a full-scale m	•
Ringhals 3 entered commercial oper	ration on September 9,	the steam generator at their	[.] lab in Älvkarleby.
1981 and is a three-loop pressurized	d water reactor built by	I was involved for measurem	nents from the start.
Westinghouse.			
-		Control room personnel from	5
Shortly after starting, problems with	n vibrations and	Water flow by two fire extin	guisher pumps used at oil
leakage in the steam generators we	re encountered, which	platforms. We had finally so	me 150 sensors in the
was solved with a minor redesign of	the inlet of these.	model, most of them under	water.
Seems like easily fixed! But	33 nuclear	From May 1982 Westinghou	se hired the model to make
		tests of suggested modificat	ions, a total of 45
power plants were involved	1:	Americans! 700 people in a	Pittsburgh Task Force.

38

谢拉	林	SEES	谢拉林	SEES
	Big drama! Westinghouse did not want me to reco anything!	rd	Westinghouse recorded s and sent the tapes to Pitt analyzers.	ignals on FM tape recorders sburgh for analysis in FFT
	"We will give Vattenfall all analysis data!"			
			I recorded and analyzed s	ignals in a 40 chl TRAS system.
	Vattenfall said "If you don't allow our consultant to	D		
	record, forget about hiring the model!"		Before the FM tapes had analysis report.	reach Arlanda, I had printed an
	A telephone call between generaldirektör Norrby	and		
	Westinghouse CEO was needed!			'Thank God that 3K recorded weeks I was in practice working ent the bills to Vattenfall!

37

SEES November 2024

SEES November 2024

